

SECTION 6

6.47 AIR AND VACUUM RELIEF VALVES:

Combination air and vacuum relief valves shall be required for Conduits and may be required for Transmission Mains at the discretion of Denver Water. Air and vacuum valve assemblies as shown on Sheet I6 of the Standard Drawings shall be installed at high points in the Conduit, where there is an abrupt change of slope and at line valves where the Conduit slopes away from the valve or as determined by Denver Water. See MS-10.